

上越工業用水道水質表

2026年8月

項目 日	原 水																	記 事	
	濁 度			p H			水 温℃			導電率μ S/cm			酸消 費量 mg/L	塩化物 イオン mg/L	全硬度 mg/L	鉄 mg/L	蒸発 残留物 mg/L		
	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低							
1	12	14	11	7.28	7.52	7.12	26.2	27.5	24.9	183	191	173	47	19	49	0.20	135		
2	12	14	11	7.27	7.49	7.11	25.7	26.6	25.0	176	179	172	48	25					
3	11	13	9	7.39	7.79	7.12	26.7	29.2	24.5	183	188	178	51	23					
4	10	12	9	7.47	7.99	7.11	27.7	30.2	25.4	188	190	183	52	22					
5	9	12	8	7.63	8.32	7.15	27.8	30.4	25.0	192	199	187	49	20					
6	9	10	7	7.72	8.53	7.09	28.4	31.1	25.5	198	208	191	48	21					
7	8	10	7	7.77	8.58	7.15	29.0	31.7	26.2	203	205	199	48	21					
8	77	717	7	7.54	8.46	7.03	28.5	30.8	26.0	193	214	128	49	23					
9	72	308	25	7.21	7.41	7.08	26.2	28.0	24.3	146	164	128	34	18					
10	15	26	12	7.43	7.90	7.11	26.9	28.7	25.4	175	184	167	46	22					
11	14	27	11	7.34	7.80	7.15	24.7	25.9	23.7	182	191	165	48	21		0.20			
12	21	32	15	7.29	7.47	7.15	24.2	26.0	22.4	165	173	156	40	16					
13	12	16	9	7.40	7.79	7.14	25.1	27.6	22.8	180	185	173	48	21					
14	11	14	9	7.49	8.03	7.18	26.3	29.0	23.9	186	191	183	53	25					
15	10	11	8	7.53	8.11	7.15	27.0	29.2	24.9	195	204	186	52	22					
16	10	11	8	7.56	8.27	7.16	26.7	28.7	25.0	191	202	183	51	20					
17	10	11	8	7.55	8.26	7.14	27.0	29.1	25.1	193	199	186	53	25					
18	9	11	8	7.59	8.26	7.15	27.2	29.0	25.3	204	214	197	52	25					
19	9	11	7	7.61	8.32	7.13	27.5	30.0	25.2	204	215	198	52	26					
20	9	11	7	7.60	8.34	7.11	27.3	28.9	25.5	204	214	196	52	25					
21	40	128	9	7.21	7.32	7.10	25.1	26.2	24.3	169	207	119	43	21	34	0.20	132		
22	50	121	19	7.21	7.32	7.09	25.1	26.9	23.6	166	193	144	44	23					
23	17	19	15	7.32	7.58	7.14	26.4	28.8	24.3	192	195	186	48	22					
24	14	16	12	7.37	7.68	7.15	27.7	30.4	25.2	203	207	195	53	24					
25	12	15	10	7.44	7.89	7.16	28.2	30.6	25.8	208	216	204	52	26					
26	16	102	9	7.37	7.88	7.14	27.6	29.9	26.1	210	220	186	54	24					
27	185	320	72	7.03	7.22	6.84	23.0	26.4	21.0	106	153	92	26	15		0.20			
28	83	133	59	7.22	7.26	7.14	21.5	22.4	20.8	112	124	103	27	13					
29	95	179	58	7.20	7.32	7.00	20.6	21.1	20.0	111	130	91	28	13					
30	60	100	39	7.25	7.31	7.18	20.8	22.3	19.5	110	123	96	26	10					
31	35	47	26	7.29	7.32	7.25	22.4	24.7	20.6	126	131	116	32	14					
最高	185	717	72	7.77	8.58	7.25	29.0	31.7	26.2	210	220	204	54	26	49	0.20	135		
最低	8	10	7	7.03	7.22	6.84	20.6	21.1	19.5	106	123	91	26	10	34	0.20	132		
平均	31	80	17	7.41	7.83	7.12	26.0	28.0	24.1	176	187	163	45	21	42	0.20	134		

上越工業用水道水質表

2 0 2 6 年 8 月

項目 日	処 理 水																	記 事	
	濁 度			p H			水 温			導電率			酸消 費量 mg/L	塩化物 イオン mg/L	全硬度 mg/L	鉄 mg/L	蒸発 残留物 mg/L		
	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低							
1	1.0	1.5	0.7	7.01	7.08	6.94	26.3	27.3	25.2	188	194	178	43	22					
2	0.9	1.2	0.7	7.04	7.11	6.98	25.9	26.6	25.2	181	182	179	46	27					
3	1.0	1.4	0.6	7.05	7.13	7.00	26.6	28.8	24.9	187	191	183	48	25					
4	0.9	1.3	0.5	7.07	7.18	6.99	27.7	29.9	25.8	193	196	190	46	24					
5	1.0	1.2	0.6	7.15	7.38	7.01	27.9	30.0	25.5	196	201	194	46	23					
6	0.9	1.8	0.3	7.10	7.33	6.93	28.5	30.8	26.1	206	210	201	47	22					
7	0.9	1.9	0.4	7.09	7.24	6.95	29.1	31.4	26.7	209	213	202	48	25	53	0.00	123		
8	0.8	2.1	0.3	7.05	7.18	6.74	29.0	30.5	27.2	206	217	167	47	25					
9	1.1	1.7	0.5	6.81	6.92	6.56	26.3	27.8	24.7	154	162	147	29	23					
10	1.1	1.9	0.8	7.03	7.21	6.88	26.9	28.3	25.7	177	183	164	42	22					
11	1.0	1.3	0.6	7.06	7.16	6.97	25.1	26.7	24.2	189	195	179	44	24					
12	1.1	2.0	0.6	6.95	7.00	6.89	24.3	25.7	22.8	171	177	165	37	20					
13	1.0	1.5	0.7	6.98	7.08	6.91	25.1	27.3	23.2	184	189	176	44	24					
14	1.0	1.4	0.6	7.04	7.18	6.97	26.3	28.6	24.4	191	194	189	52	26		0.00			
15	0.8	1.4	0.5	7.06	7.17	6.94	27.2	28.8	25.4	199	208	191	50	26					
16	0.9	1.4	0.5	7.07	7.21	6.95	26.8	28.4	25.3	199	209	190	49	22					
17	0.9	1.6	0.6	7.05	7.20	6.91	27.0	28.8	25.4	197	202	190	48	29					
18	1.0	1.5	0.7	7.09	7.23	6.93	27.3	28.8	25.7	209	218	200	50	28					
19	1.0	1.5	0.6	7.11	7.26	6.94	27.6	29.6	25.6	210	217	205	51	27					
20	0.9	1.3	0.5	7.10	7.24	6.93	27.5	28.7	25.9	209	217	204	50	28					
21	0.9	1.6	0.5	6.91	7.13	6.76	25.5	27.6	24.5	180	209	149	38	21	32	0.00	89		
22	1.3	1.7	0.7	6.78	6.88	6.69	25.0	26.6	23.9	169	189	154	39	29					
23	1.1	1.9	0.7	6.94	7.02	6.88	26.4	28.4	24.7	197	201	191	46	25					
24	1.1	1.7	0.8	7.01	7.11	6.93	27.7	30.1	25.6	208	212	198	48	27					
25	1.1	1.5	0.8	7.05	7.13	6.94	28.3	30.3	26.2	213	219	208	50	30					
26	1.0	1.4	0.7	7.03	7.11	6.92	27.9	29.4	26.4	216	223	209	48	29					
27	1.0	2.1	0.5	6.71	6.96	6.61	23.6	27.5	21.3	128	210	107	21	20					
28	1.3	1.9	0.9	6.72	6.81	6.65	21.6	22.4	20.9	118	127	112	25	15		0.00			
29	1.1	1.9	0.8	6.76	6.85	6.60	20.8	21.5	20.4	121	135	105	28	17					
30	1.1	1.5	0.7	6.74	6.86	6.70	20.8	22.1	19.7	115	128	104	24	15					
31	1.0	2.4	0.5	6.78	6.85	6.72	22.5	24.4	21.0	131	137	122	31	16					
最高	1.3	2.4	0.9	7.15	7.38	7.01	29.1	31.4	27.2	216	223	209	52	30	53	0.00	123		
最低	0.8	1.2	0.3	6.71	6.81	6.56	20.8	21.5	19.7	115	127	104	21	15	32	0.00	89		
平均	1.0	1.6	0.6	6.98	7.10	6.86	26.1	27.8	24.5	182	192	173	42	24	43	0.00	106		